

**hammond**  
POWER SOLUTIONS




LR3902  
GENERAL  
PURPOSE  
TRANSFORMER  
252L  
E50394

**LISTED**

GUELPH, ONT. BARABOO, WI COMPTON, CA MONTERREY, MX

COMMERCIAL POTTED DISTRIBUTION TRANSFORMER

HV/HT	190.....480V			Cust. Ref.	
BIL	-			Réf. du client	
TERM. BORNES	H1.....H10			Serial No.	
				No. de série	
				Part No.	C1F1COXES
				No. de pièce	
				Phase	1
				kVA	1.0
				TYPE	Q
				Cooling Refroidissement	ANC
				Temp. Class Classe de Temp.	130 °C
				Frequency Fréquence	50/60 Hz
				Impédance %	
				Encl. Type Type de boîtier	3R
				Wt POIDS lbs/kg	35.3/17
LV/BT	120V/240V				
BIL	-				
TERM. BORNES	X4	X2	X3	X1	



PRIMARY VOLTAGE	CONNECT LINES TO	INTER-CONNECT
280V (60 Hz)	H1, H10	H5-H8
400V	H1, H10	H5-H6
416V	H1, H9	H4-H8
480V	H1, H8	H4-H6
380V	H1, H7	H3-H6
240V (60 Hz)	H1, H10	H1-H5, H5-H10
220V	H1, H10	H1-H5, H5-H10
208V	H1, H9	H1-H5, H4-H9
200V	H1, H8	H1-H5, H4-H8
180V	H1, H7	H1-H5, H2-H7
SECONDARY VOLTAGE	CONNECT LINES TO	INTER-CONNECT
240V	X1, X4	X2-X3
120/240V	X1, X2, X4	X2-X3
120V	X1, X4	X2-X4, X1-X3

COMPLIES WITH EN60076-11 2004-05

ELECTROSTATIC SHIELD  
COMPLIES WITH EN60742 (1997-06)  
DEGREE OF PROTECTION: IP33  
\*THE PRIMARY VOLTAGE RATIO OF 240V OR 480V  
IS AVAILABLE AT 60 HZ ONLY WITH A SECONDARY  
VOLTAGE OF APPROXIMATELY 130/262V



d000013hdbesm

**hammond**  
POWER SOLUTIONS


TITLE: 1 PHASE ENCAPSULATED TRANSFORMER  
NAMEPLATE INFORMATION

3	26/06/23	LC	CHANGED NPL VER:	DES: LCEN
2	21/07/13	PP	EDB UPDATE	DATE: 08/10/17
NO.	DATE	BY	REVISION	SCALE: NTS


SHEET 1 OF 2  
EBC1F1COXES

3.0 httpd 2026/06/24 23:49 THIS DRAWING CONTAINS STRICTLY CONFIDENTIAL INFORMATION BELONGING TO HAMMOND POWER SOLUTIONS AND MUST NOT BE DISTRIBUTED OUTSIDE AUTHORIZED PARTIES.

FRONT VIEW



SIDE VIEW



FRONT & BOTTOM PANEL IS HINGED FOR ACCESS TO TERMINALS, BOTTOM MOUNTING HOLES AND REAR KNOCKOUT.

All Dimensions in inches

ENCLOSURE COLOR : ANSI 61 GREY – OUTDOOR

CUSTOMER NOTES:

- HV1 TERMINATED AT LEADS
- LV1 TERMINATED AT LEADS



TITLE: 1 PHASE ENCAPSULATED TRANSFORMER

3	26/06/23	LC	CHANGED NPL VER:	DES: LCEN
2	21/07/13	PP	EDB UPDATE	DATE: 08/10/17
NO.	DATE	BY	REVISION	SCALE: NTS

SHEET 2 OF 2

EDBC1F1C0XES