



HPS CENTURION R 3PH DRY TYPE REACTOR

CRX10D7CC

1.6 MH 50/60 HZ 10.7 AMPS 0.6 KV CLASS TEMP CLASS: 130 TYPE JR-1 TERMINAL TORQUE: 11 LB-IN AMBIENT: 50°C

NOTES:



				,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,
TITLE:			3 PHASE LINE REA	SHEET 1 SHEET 1
				I DEC. DRAVED C
				DATE: 14/06/25
NO.	DATE	BY	REVISION	SCALE: NTS