



® LR 3902

UL DRY TYPE TRANSFORMER 774J5 E112313

LISTED

GUELPH, ONT. BARABOO, WI COMPTON, CA MONTERREY, MX

THREE PHASE DRY TYPE DRIVE ISOLATION TRANSFORMER
TRANSFORMATEUR TRIPHASE POUR VARIATEUR DE VITESSE DE MOTEURS

| | | | | | | |
|--------------|-------------------|----------------------|---|--|--------------------------------|---------|
| HV/HT | 480V | | | | Cust. Ref. Réf. du client | |
| BIL | - | | | | Serial No. No. de série | |
| TERM. BORNES | H1 H2 H3 | | | | Part No. No. de pièce | DM027KK |
| | VOLTS | CURRENT COURANT | % RATED VOLTAGE % TENSION NOMINALE | CONNECTION EACH PHASE CONNEXION PAR PHASE | kVA | 27 |
| | 504 480 456 | 30.9 32.5 34.2 | 105 100 95 | 1 2 3 | TYPE | K |
| | 480Y/277V | | | | Cooling Refroidissement | ANN |
| LV/BT | | | | | Temp. Rise Echauffement | 150 °C |
| BIL | - | | | | Temp. Class Classe de Temp. | 220 °C |
| TERM. BORNES | X0 X1 X2 X3 | | | | Frequency Fréquence | 60 Hz |
| | | | | | Impédance % @ 170 °C | 4.8 |
| | | | | | Encl. Type Type de boîtier | 3R |
| | | | | | Wt Poids | 295 lbs |
| | | | | | Winding Enroulement | AL |



SPACINGS BETWEEN ANY VENTILATED ENCLOSURE PANEL AND ANY ADJACENT WALL SHALL BE A MINIMUM OF 3 INCHES

d003102b



THIS DRAWING CONTAINS STRICTLY CONFIDENTIAL INFORMATION BELONGING TO HAMMOND POWER SOLUTIONS AND MUST NOT BE DISTRIBUTED OUTSIDE AUTHORIZED PARTIES.



TITLE: 3PH DRIVE TRANSFORMER
NAMEPLATE INFORMATION

| | | | | |
|-----|----------|----|--------------------------------|----------------|
| 2 | 21/07/16 | PP | EDB UPDATE | DES: MBURSAC |
| 1 | 20/03/03 | CS | ENCLOSURE UPDATED TO NEW STYLE | DATE: 01/01/29 |
| NO. | DATE | BY | REVISION | SCALE: NTS |

SHEET 1 OF 2

EDBDM027KK

2.0 httpd 2026/05/22 13:09



All Dimensions in inches

ENCLOSURE COLOR : ANSI 61 GREY – OUTDOOR

HV TERMINAL DETAIL

LV TERMINAL DETAIL

MECHANICAL TYPE LUGS INCLUDED
SUITABLE FOR #14-2 CU/AL
CONDUCTORS
1 CONDUCTOR PER PHASE

MECHANICAL TYPE LUGS INCLUDED
SUITABLE FOR #14-2 CU/AL
CONDUCTORS
1 CONDUCTOR PER PHASE

CUSTOMER NOTES:

- HV TERMINATED AT TOP FRONT
- LV TERMINATED AT BOTTOM FRONT
- C/W 1-”NC”- THERMOSTAT PER COIL CONNECTED TO T.B.



TITLE: 3PH DRIVE TRANSFORMER

| | | | | |
|-----|----------|----|--------------------------------|----------------|
| 2 | 21/07/16 | PP | EDB UPDATE | DES: MBURSAC |
| 1 | 20/03/03 | CS | ENCLOSURE UPDATED TO NEW STYLE | DATE: 01/01/29 |
| NO. | DATE | BY | REVISION | SCALE: NTS |

SHEET 2 OF 2

EDBDM027KK