



® LR 3902

UL DRY TYPE TRANSFORMER 774J5 E112313

LISTED

GUELPH, ONT. BARABOO, WI COMPTON, CA MONTERREY, MX

THREE PHASE DRY TYPE DRIVE ISOLATION TRANSFORMER
TRANSFORMATEUR TRIPHASE POUR VARIATEUR DE VITESSE DE MOTEURS

HV/HT	460V				Cust. Ref. Réf. du client	
BIL	-				Serial No. No. de série	
TERM. BORNES	H1 H2 H3				Part No. No. de pièce	DM034JJ
	VOLTS	CURRENT COURANT	% RATED VOLTAGE % TENSION NOMINALE	CONNECTION EACH PHASE CONNEXION PAR PHASE	kVA	34
	483	40.6	105	1	TYPE	K
	460	42.7	100	2	Cooling Refroidissement	ANN
	437	44.9	95	3	Temp. Rise Echauffement	150 °C
					Temp. Class Classe de Temp.	220 °C
					Frequency Fréquence	60 Hz
					Impédance % @ 170 °C	5.7
LV/BT	460Y/266V				Encl. Type Type de boîtier	3R
BIL	-				Wt Poids	325 lbs
TERM. BORNES	X0 X1 X2 X3				Winding Enroulement	AL



SPACINGS BETWEEN ANY VENTILATED ENCLOSURE PANEL AND ANY ADJACENT WALL SHALL BE A MINIMUM OF 3 INCHES

4003102b



TITLE: 3PH DRIVE TRANSFORMER
NAMEPLATE INFORMATION

4	21/07/13	PP	EDB UPDATE	DES: GCALOTA
3	15/06/16	ME	HCN: 60135	DATE: 02/03/22
NO.	DATE	BY	REVISION	SCALE: NTS

SHEET 1 OF 2

EDBDM034JJ

FRONT VIEW

SIDE VIEW



All Dimensions in inches

ENCLOSURE COLOR : ANSI 61 GREY – OUTDOOR

HV TERMINAL DETAIL

LV TERMINAL DETAIL

MECHANICAL TYPE LUGS INCLUDED
SUITABLE FOR #14-2 CU/AL
CONDUCTORS
1 CONDUCTOR PER PHASE

MECHANICAL TYPE LUGS INCLUDED
SUITABLE FOR #14-2 CU/AL
CONDUCTORS
1 CONDUCTOR PER PHASE

CUSTOMER NOTES:

- HV TERMINATED AT TOP FRONT
- LV TERMINATED AT BOTTOM FRONT
- C/W 1-"NC"- THERMOSTAT PER COIL CONNECTED TO T.B.



TITLE: 3PH DRIVE TRANSFORMER

4	21/07/13	PP	EDB UPDATE	DES: GCALOTA
3	15/06/16	ME	HCN: 60135	DATE: 02/03/22
NO.	DATE	BY	REVISION	SCALE: NTS

SHEET 2 OF 2

EDBDM034JJ