



LR 3902


UL DRY TYPE TRANSFORMER 77JUS E112313

LISTED

GUELPH, ONT. BARABOO, WI COMPTON, CA MONTERREY, MX

THREE PHASE DRY TYPE TRANSFORMER  
TRANSFORMATEUR SEC TRIPHASE

HV/HT	480Y/277V				Cust. Ref. Réf. du client	
BIL	-				Serial No. No. de série	
TERM. BORNES	H0 H1 H2 H3				Part No. No. de pièce	DM093BK
	VOLTS	CURRENT COURANT	% RATED VOLTAGE % TENSION NOMINALE	CONNECTION EACH PHASE CONNEXION PAR PHASE	kVA	93
	218 208 198	246 258 272	105 100 95	1 2 3	TYPE	K
	208V				Cooling Refroidissement	ANN
LV/BT					Temp. Rise Echauffement	150 °C
BIL	-				Temp. Class Classe de Temp.	220 °C
TERM. BORNES	X1 X2 X3				Frequency Fréquence	60 Hz
					Impédance % @ 170 °C	4.1
					Encl. Type Type de boîtier	3R
					Wt Poids	635 lbs
					Winding Enroulement	AL



SPACINGS BETWEEN ANY VENTILATED ENCLOSURE PANEL AND ANY ADJACENT WALL SHALL BE A MINIMUM OF 5 INCHES EXCEPT WHEN WALL MOUNTED USING APPROVED WALL MOUNTING KIT  
TRANSFORMER SUITABLE FOR STEP UP OPERATION ONLY

47003002b



TITLE: 3PH DISTRIBUTION TRANSFORMER  
NAMEPLATE INFORMATION

2	21/07/13	PP	EDB UPDATE	DES: GPATEL
1	14/04/14	DC	UPDATED DWGS(HCN 48807)	DATE: 01/06/04
NO.	DATE	BY	REVISION	SCALE: NTS

SHEET 1 OF 2

EDBDM093BK

THIS DRAWING CONTAINS STRICTLY CONFIDENTIAL INFORMATION BELONGING TO HAMMOND POWER SOLUTIONS AND MUST NOT BE DISTRIBUTED OUTSIDE AUTHORIZED PARTIES.  
2.0 http://www.hammond.com/2026/04/18/21:29



All Dimensions in inches



ENCLOSURE COLOR :ANSI 61 GREY- OUTDOOR

H.V.1. TERMINAL DETAIL

L.V.1. TERMINAL DETAIL

MECHANICAL TYPE LUGS INCLUDED  
SUITABLE FOR 250MCM-6 CU/AL  
CONDUCTORS  
1 CONDUCTOR PER PHASE

MECHANICAL TYPE LUGS INCLUDED  
SUITABLE FOR 600MCM-2 CU/AL  
CONDUCTORS  
1 CONDUCTOR PER PHASE

CUSTOMER NOTES:

- HV1 TERMINATED AT BOTTOM FRONT
- LV1 TERMINATED AT TOP FRONT
- C/W 1-"NC"- THERMOSTAT PER COIL CONNECTED TO T.B.



TITLE: 3PH DISTRIBUTION TRANSFORMER				
2	21/07/13	PP	EDB UPDATE	DES: GPATEL
1	14/04/14	DC	UPDATED DWGS(HCN 48807)	DATE: 01/06/04
NO.	DATE	BY	REVISION	SCALE: NTS

SHEET 2 OF 2  
EDBDM093BK  
2.0 httpd 2026/04/18 21:29