



TITLE: 1PH DISTRIBUTION TRANSFORMER  
NAMEPLATE INFORMATION

2	21/07/16	PP	EDB UPDATE	DES: RMOVVA
1	19/07/30	RM	CHANGED NPL VER:	DATE: 16/05/03
NO.	DATE	BY	REVISION	SCALE: NTS

SHEET 1 OF 2

EDBMG2L0037SESAHCO

2.0 http://www.hammond.com/2026/04/02/10:27

THIS DRAWING CONTAINS STRICTLY CONFIDENTIAL INFORMATION BELONGING TO HAMMOND POWER SOLUTIONS AND MUST NOT BE DISTRIBUTED OUTSIDE AUTHORIZED PARTIES.

**hammond**  
POWER SOLUTIONS

Distribution Transformer  
Transformateur de Distribution

LR 3902  
DISTRIBUTION TRANSFORMER  
E147879 ALSO VERIFIED IN ACCORDANCE  
TO ENERGY STANDARD CB02.2-12  
**LISTED**

Hyderabad, IN    Guelph, ONT    Baraboo, WI    Spangings BETWEEN ANY VENTILATED ENCLOSURE PANEL AND ANY ADJACENT WALL SHALL BE A MINIMUM OF 3 INCHES

Compton, CA    Monterrey, MX    Part No. MG2L0037SESAHCO

Cust. Ref. Ref. du Client	Serial No. No. de Serie	VOLTS	CURRENT COURANT	% RATED VOLTAGE % NOMINALE	CONNECTION FOR CONNECTION PAR PHASE
1	HV/HT	4368	8.6	105	1-2
F	BIL	4264	8.8	102.5	2-3
ANN	Term Bornes	4160	9.0	100	3-4
37.5	LV/BT	4056	8.2	97.5	4-5
150 °C		3952	9.5	95	5-6
220 °C					
AL					
60					
5					
3R					
440					

4160V    9.0 A    30 kV    H1 H2    120/240V    312.5,156A    10 kV    X4 X2 X3 X1

DOE 10 CFR PART 431:2016    CEE ACT SOR/2011-182

d000590hb



All Dimensions in inches

ENCLOSURE COLOR : ANSI 61 GREY – OUTDOOR

H.V.1. TERMINAL DETAIL

L.V.1. TERMINAL DETAIL

MECHANICAL TYPE LUGS INCLUDED  
SUITABLE FOR #14-2 CU/AL  
CONDUCTORS  
1 CONDUCTOR PER PHASE

MECHANICAL TYPE LUGS INCLUDED  
SUITABLE FOR 250MCM-6 CU/AL  
CONDUCTORS  
1 CONDUCTOR PER PHASE

CUSTOMER NOTES:

- HV1 TERMINATED AT TOP FRONT
- LV1 TERMINATED AT BOTTOM FRONT



TITLE: 1PH DISTRIBUTION TRANSFORMER

2	21/07/16	PP	EDB UPDATE	DES: RMOVVA
1	19/07/30	RM	CHANGED NPL VER:	DATE: 16/05/03
NO.	DATE	BY	REVISION	SCALE: NTS

SHEET 2 OF 2

EDBMC210037SESAHCO