



TITLE: 1PH DISTRIBUTION TRANSFORMER  
NAMEPLATE INFORMATION

1	21/07/16	PP	EDB UPDATE	DES: RMOVVA
NO.	DATE	BY	REVISION	SCALE: NTS

SHEET 1 OF 2

EDBMG210075RESAHC0

1.0 httpd 2026/04/01 10:38

THIS DRAWING CONTAINS STRICTLY CONFIDENTIAL INFORMATION BELONGING TO HAMMOND POWER SOLUTIONS AND MUST NOT BE DISTRIBUTED OUTSIDE AUTHORIZED PARTIES.

**hammond**  
POWER SOLUTIONS

Distribution Transformer  
Transformateur de Distribution

LR 3902  
DISTRIBUTION TRANSFORMER  
E147879

ALSO VERIFIED IN ACCORDANCE  
TO ENERGY STANDARD C802.2-18  
BY UNDERWRITERS LABORATORIES INC. 3106

**LISTED**


Hyderabad, IN    Guelph, ONT    Baraboo, WI    Spangings BETWEEN ANY VENTILATED ENCLOSURE PANEL AND ANY ADJACENT WALL SHALL BE A MINIMUM OF 3 INCHES

Compton, CA    Monterrey, MX    Part No. MG2L0075RESAHC0    120V LINK X4-X2 & X3-X1  
240V LINK X2-X3


Cust. Ref. Ref. du Client	Serial No. No. de Serie	VOLTS	% RATED VOLTAGE % NOMINALE	CONNECTION FOR CONNECTION PAR PHASE	
1	HV/HT	2400V	105	1-2	
F	BIL	20 kV	102.5	2-3	
ANN	Term Bornes	H1 H2	100	3-4	
75	LV/BT	120/240V	97.5	4-5	
150 °C	BIL	10 kV	95	5-6	
220 °C	Term Bornes	X4 X2 X3 X1			
AL	Energy Regulations	DOE 10 CFR PART 431:2016			
60	Reglements Energetique	CEE ACT SOR/2018-201			
4.2					
3R	End. Type/Category Type ou categorie de boitier				
645/293	Weight lbs/kg Poids				

CURRENT COURANT	% RATED VOLTAGE % NOMINALE	CONNECTION FOR CONNECTION PAR PHASE
29.8	105	1-2
30.5	102.5	2-3
31.2	100	3-4
32.1	97.5	4-5
32.9	95	5-6

d000590hb




All Dimensions in inches




ENCLOSURE COLOR :ANSI 61 GREY- OUTDOOR

HV TERMINAL DETAIL



LV1 TERMINAL DETAIL



CUSTOMER NOTES:

- HV TERMINATED AT TOP FRONT
- LV1 TERMINATED AT BOTTOM FRONT



TITLE: 1PH DISTRIBUTION TRANSFORMER

1	21/07/16	PP	EDB UPDATE	DES: RMOVVA
NO.	DATE	BY	REVISION	SCALE: NTS

SHEET 2 OF 2

EDBMC21007FRESAHC0