



TITLE: 1PH DISTRIBUTION TRANSFORMER
NAMEPLATE INFORMATION

1	21/07/16	PP	EDB UPDATE	DES: DCORTEZ
NO.	DATE	BY	REVISION	SCALE: NTS

SHEET 1 OF 2

EDBMG210075SESAHCO

1.0 httpd 2026/06/04 14:56

THIS DRAWING CONTAINS STRICTLY CONFIDENTIAL INFORMATION BELONGING TO HAMMOND POWER SOLUTIONS AND MUST NOT BE DISTRIBUTED OUTSIDE AUTHORIZED PARTIES.

hammond
POWER SOLUTIONS

Distribution Transformer
Transformateur de Distribution

LR 3902
DISTRIBUTION TRANSFORMER
E147879

ALSO VERIFIED IN ACCORDANCE
TO ENERGY STANDARD C802.2-18
BY UNDERWRITERS LABORATORIES INC. 3166

LISTED

Hyderabad, IN Guelph, ONT Baraboo, WI Spangings BETWEEN ANY VENTILATED ENCLOSURE PANEL AND ANY ADJACENT WALL SHALL BE A MINIMUM OF 3 INCHES
Compton, CA Monterrey, MX Part No. MG2L0075SESAHCO

Cust. Ref. Ref. du Client	Serial No. No. de Serie	HV/HT	18.0A	VOLTS	% RATED VOLTAGE % NOMINALE	CONNECTION FOR CONNECTION PAR PHASE
Phase	1	BIL	30 kV	4368	105	1-2
Type	F	Term Bornes	H1 H2	4264	102.5	2-3
Cooling Refrondissement	ANN	LV/BT	120/240V	4160	100	3-4
kVA	75	BIL	10 kV	4056	97.5	4-5
Temp. Rise Echauffement	150 °C	Term Bornes	X4 X2 X3 X1	3952	95	5-6
Temp Class Classe Temp	220 °C	Energy Regulations Reglements Energetique	DOE 10 CFR PART 431:2016			
Winding Enroulement	AL	CEE ACT SOR/2018-201				
Frequency Frequence Hz	60					
Impedance % @ 170 °C	4.9					
End. Type/Category Type ou categorie de boitier	3R					
Weight Poids	665					

d000590hb




All Dimensions in inches




ENCLOSURE COLOR :ANSI 61 GREY- OUTDOOR

HV TERMINAL DETAIL



LV TERMINAL DETAIL



CUSTOMER NOTES:

- HV TERMINATED AT TOP FRONT
- LV TERMINATED AT BOTTOM FRONT



TITLE: 1PH DISTRIBUTION TRANSFORMER				
1	21/07/16	PP	EDB UPDATE	DES: DCORTEZ
NO.	DATE	BY	REVISION	SCALE: NTS

SHEET 2 OF 2

EDBMG210075SESAC0