



TITLE: 1PH DISTRIBUTION TRANSFORMER.
NAMEPLATE INFORMATION

3	23/03/09	DC	UPDATED	TOTAL WEIGHT(HCN: 78486)	DES: RMOVVA
2	21/07/16	PP		EDB UPDATE	DATE: 16/08/11
NO.	DATE	BY	REVISION		SCALE: NTS

SHEET 1 OF 1

EDBMG2L0150RESAHC0

3.0 httpd 2026/06/25 00:20

THIS DRAWING CONTAINS STRICTLY CONFIDENTIAL INFORMATION BELONGING TO HAMMOND POWER SOLUTIONS AND MUST NOT BE DISTRIBUTED OUTSIDE AUTHORIZED PARTIES.

hammond POWER SOLUTIONS

Guelph, ONT Compton, CA Baraboo, WI
Hyderabad, IN Monterrey, MX

hammond Distribution Transformer
Transformateur de Distribution

Part No. MG2L0150RESAHC0

LR 3902

LISTED

8 03423 13316 0

ALSO VERIFIED IN ACCORDANCE
TO ENERGY STANDARD C802.2-18
BY UNDERWRITERS LABORATORIES INC. 3106

Cust. Ref. Ref. du Client	MVIS150RE	Serial No. No. de Serie	2400V	62.5A	
Phase	1	HV/HT	20 kV		
Type	F	BIL	H1 H2		
Cooling Refrondissement	ANN	Term Bornes	120/240V	625A	
kVA	150	LV/BT	10 kV		
Temp. Rise Echauffement	150 °C	BIL	X4 X2 X3 X1		
Temp Class Classe Temp	220 °C	Term Bornes	DOE 10 CFR PART 431:2016		
Winding Enroulement	AL	Energy Regulations	CEE ACT SOR/2018-201		
Frequency Frequence Hz	60	Reglements de			
Impedance % @ 170 °C	6.5	Energetique			
End. Type/Category Type ou categorie de boitier	3R				
Weight lbs/kg Poids	1070/486				

SPACINGS BETWEEN ANY VENTILATED ENCLOSURE PANEL AND ANY ADJACENT WALL SHALL BE A MINIMUM OF 5 INCHES

BOTH SETS OF HV TAPS MUST BE ON SAME CONNECTION

BOTH H2 JUMPERS ON SAME TAP ON BOTH COILS

SECONDARY VOLTS
120V LINK X4-X2 & X3-X1
240V LINK X2-X3

VOLTS	CURRENT COURANT	% RATED VOLTAGE NOMINALE	CONNECTION FOR CONNECTION PAR PHASE
2520	59.5	105	1
2460	61.0	102.5	2
2400	62.5	100	3
2340	64.1	97.5	4
2280	65.8	95	5

d000590hb