

- IMPEDANCE SHOWN IS CALCULATED VALUE - NOT GUARANTEED

d000590hb




LR 3902
DISTRIBUTION TRANSFORMER
E147879
ALSO VERIFIED IN ACCORDANCE TO ENERGY STANDARD C802.2-18 BY UNDERWRIERS LABORATORIES INC. 3106
LISTED

hammond Distribution Transformer
POWER SOLUTIONS Transformateur de Distribution
Guelph, ONT Baraboo, WI
Compton, CA Monterrey, MX
Hyderabad, IN Part No. MG2L0333RESAHC0

Cust. Ref. Ref. du Client	Serial No. No. de Serie	CONNECTION FOR CONNECTION PAR PHASE	
Phase	HV/HT	% RATED VOLTAGE NOMINALE	1 2 3 4 5
Type	BIL	CURRENT COURANT	
Cooling Refroidissement	Term Bornes	VOLTS	
kVA	LV/BT	2520	
Temp. Rise Echauffement	BIL	2460	
Temp Class Classe Temp	Term Bornes	2400	
Winding Enroulement	Energy Regulations Reglements Energetique	2340	
Frequency Fréquence Hz	DOE 10 CFR PART 431:2016	2280	
Impedance % @ 170°C	CEE ACT SOR/2018-201		
End. Type/Category Type ou catégorie de boîtier			
Weight lbs/kg Poids			

SPACINGS BETWEEN ANY VENTILATED ENCLOSURE PANEL AND ANY ADJACENT WALL SHALL BE A MINIMUM OF 5 INCHES
BOTH H2 JUMPERS MUST BE ON SAME TAP- BOTH COILS
SECONDARY VOLTS
120V LINK X4-X2 & X3-X1
240V LINK X2-X3



TITLE: 1PH DISTRIBUTION TRANSFORMER NAMEPLATE INFORMATION		DES: DCORTEZ
NO.	DATE	DATE: 21/10/29
BY	REVISION	SCALE: NTS

SHEET 1 OF 1
EDBMG2L0333RESAHC0
0.1 httpd 2026/06/06 21:07

THIS DRAWING CONTAINS STRICTLY CONFIDENTIAL INFORMATION BELONGING TO HAMMOND POWER SOLUTIONS AND MUST NOT BE DISTRIBUTED OUTSIDE AUTHORIZED PARTIES.