


- IMPEDANCE SHOWN IS CALCULATED VALUE - NOT GUARANTEED

d000590hb




**hammond**  
POWER SOLUTIONS

Distribution Transformer  
Transformateur de Distribution

Part No. MG2L0333RESAHC0


Guelph, ONT  
Compton, CA

Baraboo, WI  
Monterrey, MX



LR 3902  
DISTRIBUTION TRANSFORMER  
E147879

ALSO VERIFIED IN ACCORDANCE  
TO ENERGY STANDARD C802.2-18  
BY UNDERWRITERS LABORATORIES INC. 3106




8 03423 13319 1

VOLTS	CURRENT COURANT	% RATED VOLTAGE % NOMINALE	CONNECTION FOR CONNECTION PAR PHASE
2520	132.2	105	1
2460	135.4	102.5	2
2400	138.8	100	3
2340	142.4	97.5	4
2280	146.0	95	5

SPACINGS BETWEEN ANY VENTILATED ENCLOSURE PANEL AND ANY ADJACENT WALL SHALL BE A MINIMUM OF 5 INCHES  
BOTH H2 JUMPERS MUST BE ON SAME TAP- BOTH COILS

SECONDARY VOLTS  
120V LINK X4-X2 & X3-X1  
240V LINK X2-X3





TITLE:		1PH DISTRIBUTION TRANSFORMER NAMEPLATE INFORMATION	
NO.	DATE	BY	REVISION

SHEET 1 OF 1

DES: DCORTEZ  
DATE: 21/10/29  
SCALE: NTS

EDBMC2L0333RESAHC0