


- IMPEDANCE SHOWN IS CALCULATED VALUE - NOT GUARANTEED

d000590hb




**POWER SOLUTIONS**

Distribution Transformer  
Transformateur de Distribution

Part No. MG2L0333SESCHCO

Hyderabad, IN    Guelph, ONT    Baraboo, WI    Monterrey, MX



LR 3902

DISTRIBUTION TRANSFORMER E147879 ALSO VERIFIED IN ACCORDANCE TO ENERGY STANDARD CB02.2-12

**LISTED**

SPACINGS BETWEEN ANY VENTILATED ENCLOSURE PANEL AND ANY ADJACENT WALL SHALL BE A MINIMUM OF 8.25 INCHES

SECONDARY VOLTS  
120V LINK X4-X2 & X3-X1  
240V LINK X2-X3

VOLTS	CURRENT COURANT	% RATED VOLTAGE NOMINALE	CONNECTION FOR CONNECTION PAR PHASE
4368	76.3	105	1
4264	78.1	102.5	2
4160	80.0	100	3
4056	82.1	97.5	4
3952	84.3	95	5




Diagram showing primary windings (H1, H2) and secondary windings (X1, X2, X3, X4) with taps and connections.

Serial No.	4160V
HV/HT	30 kV
BIL	H1 H2
Term Bornes	120/240V
LV/BT	10 kV
BIL	X4 X2 X3 X1
Term Bornes	DOE 10 CFR PART 431:2016
Energy Regulations	CEE ACT SOR/2011-182
Reglements Energetique	

Cust. Ref. Ref. du Client	1
Phase	F
Type	ANN
Cooling Refroidissement	333
kVA	150 °C
Temp. Rise Echauffement	220 °C
Temp Class Classe Temp	CU
Winding Enroulement	60
Frequency Fréquence Hz	5.5
Impedance % @ 170 °C	3R C
End. Type/Category Type ou catégorie de boîtier	2050
Weight Poids	



TITLE: 1PH DISTRIBUTION TRANSFORMER NAMEPLATE INFORMATION	
1	21/07/16 PP EDB UPDATE DES: DCORTEZ
NO.	DATE BY REVISION SCALE: NTS

SHEET 1 OF 1

EDBMG2L0333SESCHCO

1.0 httpd 2026/06/03 13:03

THIS DRAWING CONTAINS STRICTLY CONFIDENTIAL INFORMATION BELONGING TO HAMMOND POWER SOLUTIONS AND MUST NOT BE DISTRIBUTED OUTSIDE AUTHORIZED PARTIES.