



All Dimensions in inches



ENCLOSURE COLOR :ANSI 61 GREY – OUTDOOR

HV TERMINAL DETAIL

LV TERMINAL DETAIL

MECHANICAL TYPE LUGS INCLUDED
SUITABLE FOR #14-2 CU/AL
CONDUCTORS
1 CONDUCTOR PER PHASE

MECHANICAL TYPE LUGS INCLUDED
SUITABLE FOR 350MCM-6 CU/AL
CONDUCTORS
2 CONDUCTORS PER PHASE

CUSTOMER NOTES:

- HV TERMINATED AT TOP FRONT
- LV TERMINATED AT BOTTOM FRONT



TITLE: 3PH DISTRIBUTION TRANSFORMER.

3	22/02/02	DC	REMOVED SEISMIC NOTE	DES: DCORTEZ
2	21/07/16	PP	EDB UPDATE	DATE: 18/04/13
NO.	DATE	BY	REVISION	SCALE: NTS

SHEET 2 OF 3

EDBMG3A01129BSC00



NOTE:
 WHEN BOTTOM CABLE ENTRY IS OPTED, THE SPACE USED FOR CONDUITS IN THE FRONT OF THE TRANSFORMER SHOULD NOT OBSTRUCT MORE THAN 50% OF THE FRONT AIR INTAKE AREA DEFINED BETWEEN THE BOTTOM PLATE AND THE SUPPORTING LEGS.
 SEE MANUAL FOR ADDITIONAL INFORMATION



TITLE: 3PH DISTRIBUTION TRANSFORMER.
 ENCLOSURE BOTTOM VIEW

3	22/02/02	DC	REMOVED SEISMIC NOTE	DES: DCORTEZ
2	21/07/16	PP	EDB UPDATE	DATE: 18/04/13
NO.	DATE	BY	REVISION	SCALE: NTS

SHEET 3 OF 3

EDBMG3A01129BSC00