




TITLE: 3PH DISTRIBUTION TRANSFORMER
NAMEPLATE INFORMATION

NO.	DATE	BY	REVISION	SCALE:
3	21/07/16	PP	EDB UPDATE	DES: LCEN
2	20/03/17	PP	SEISMIC UPDATE	DATE: 19/04/08
				SCALE: NTS

SHEET 1 OF 3

EDB SH310045PB3S

3.0 httpd 2026/06/03 22:08



POWER SOLUTIONS
Guelph, ONT Compton, CA
Hyderabad, IN

hammond HPS Sentinel™ H
DRY TYPE HARMONIC MITIGATING TRANSFORMER
TRANSFORMATEUR À SEC POUR MITIGATION D'HARMONIQUES
Baraboo, WI Monterrey, MX
Part No. SH310045PB3S

Cust. Ref. [] Serial No. []
Ref. du Client [] No. de Serie []

Phase 3 Model []

Type K HV/HT 600V

Cooling Refroidissement ANN Term Bornes H1 H2 H3

kVA 45 LV/BT 208Z/120V

Temp. Rise Echauffement 150 °C Term Bornes X1 X2 X3

Temp Class Classe Temp 220 °C Neutral X0(200%)

Winding Enroulement AL Energy Regulations DOE 10 CFR PART 431:2016

Frequency Fréquence Hz 60 Reglements de l'énergie CEE ACT SOR/2018-201

Impedance % @ 170 °C 4.3 Z₀ 0.95 MAX

Encl Type Type De Coffrage 3R Number of Secondaries []


Weight Poids lbs 530

VOLTS	CURRENT COURANT	% RATED VOLTAGE % NOMINALE	CONNECTION CONNECTION PAR PHASE
630	41.2	105	1
615	42.2	102.5	2
600	43.3	100	3
585	44.4	97.5	4
570	45.6	95	5
555	46.8	92.5	6
540	48.1	90	7

SEISMIC QUALIFICATIONS:
AS FLOOR MOUNT ONLY
IBC 2018/ASCE 7-16
SDS<=2.0g Z/n=1 Ip=1.5

SPACINGS BETWEEN ANY VENTILATED ENCLOSURE PANEL AND ANY ADJACENT WALL SHALL BE A MINIMUM OF 3 INCHES ELECTROSTATIC SHIELD

LISTED



DRY TYPE TRANSFORMER 8 03423 13492 1
ALSO VERIFIED IN ACCORDANCE TO ENERGY STANDARD CRO02-18 BY UNDERWITERS LABORATORIES INC. 3106

d000190hb

THIS DRAWING CONTAINS STRICTLY CONFIDENTIAL INFORMATION BELONGING TO HAMMOND POWER SOLUTIONS AND MUST NOT BE DISTRIBUTED OUTSIDE AUTHORIZED PARTIES.



All Dimensions in inches

ENCLOSURE COLOR :ANSI 61 GREY – OUTDOOR

HV TERMINAL DETAIL

LV TERMINAL DETAIL

X0 TERMINAL DETAIL

MECHANICAL TYPE LUGS INCLUDED
SUITABLE FOR #14-2 CU/AL
CONDUCTORS
1 CONDUCTOR PER PHASE

MECHANICAL TYPE LUGS INCLUDED
SUITABLE FOR 250MCM-6 CU/AL
CONDUCTORS
1 CONDUCTOR PER PHASE

MECHANICAL TYPE LUGS INCLUDED
SUITABLE FOR 600MCM-2 CU/AL
CONDUCTORS
1 CONDUCTOR PER PHASE

CUSTOMER NOTES:

- HV TERMINATED AT TOP FRONT
- LV TERMINATED AT BOTTOM FRONT
- X0 TERMINATED AT BOTTOM FRONT
- 200% RATING NEUTRAL



TITLE: 3PH DISTRIBUTION TRANSFORMER				
3	21/07/16	PP	EDB UPDATE	DES: LCEN
2	20/03/17	PP	SEISMIC UPDATE	DATE: 19/04/08
NO.	DATE	BY	REVISION	SCALE: NTS

SHEET 2 OF 3

EDBSH310045PB3S

ENCLOSURE BOTTOM VIEW



NOTE:
 WHEN BOTTOM CABLE ENTRY IS OPTED, THE SPACE USED FOR CONDUITS IN THE FRONT OF THE TRANSFORMER SHOULD NOT OBSTRUCT MORE THAN 50% OF THE FRONT AIR INTAKE AREA DEFINED BETWEEN THE BOTTOM PLATE AND THE SUPPORTING LEGS.
 SEE MANUAL FOR ADDITIONAL INFORMATION



TITLE: 3PH DISTRIBUTION TRANSFORMER
 ENCLOSURE BOTTOM VIEW

3	21/07/16	PP	EDB UPDATE	DES: LCEN
2	20/03/17	PP	SEISMIC UPDATE	DATE: 19/04/08
NO.	DATE	BY	REVISION	SCALE: NTS

SHEET 3 OF 3

EDBSH310045PB3S